



Prüfinstitut für  
Abwassertechnik  
GmbH

## PERFORMANCE RESULTS

Portapura Limited.  
Irthlingborough,  
Northants NN9, Great Britain

**EN 858-1**  
Separator systems for light liquids (e.g. oil and petrol)

### "Marator Separator"

Test report PIA2018-AB-1804-1026.01

Material	Glass reinforced plastic
Nominal hydraulic load	6.0 l/s
Nominal Size	6
Effluent	< 0.1 mg/l
Class	I

Performance tested by:

**PIA – Prüfinstitut für Abwassertechnik GmbH**  
(PIA GmbH)  
Hergenrather Weg 30  
52074 Aachen, Germany

This document replaces neither the declaration  
of performance nor the CE marking.



Notified Body  
No. 1739



Certified according to  
ISO 9001:2008



Deutsche  
Akkreditungsstelle  
D-PL-17712-01-00



Daniel Verschitz August 2018