



Certificate

Marsh Industries Ltd.

Units 2-20 Addington Park Industrial estate, Little Addington, NN14 4AS
Northants, Great Britain

British Water Code of Practice

Assessment of a Manufactured Treatment Device Designed to Treat Surface
Water Runoff

Light liquid separator NSFR6

Connected surface area: 340 m²

Test report PIA2020-NW-2009-1039

Particle retention (Millisil W4)	84.35%
Total metal reduction*	63.26%
Dissolved metal reduction	0%
Particulate metal reduction*	0.75 x 84.35%

*according to British Water „How to Guide: Applying the CIRIA SuDS Manual Simple Index Approach to Proprietary/ Manufactured Stormwater Treatment Devices, Section 4 (British Water 2019, under review)

Performance tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH

Hergenrather Weg 30
52074 Aachen
Germany

This document does not replace the test report.



Schmitz/Verschitz January 2021