



Marsh Industries Ltd.

Units 2-20 Addington Park Industrial estate, Little Addington, NN14 4AS
Northants, Great Britain

**Test Conducted to Assess the Performance & Mitigation Ratios of the
Marsh NSFR6 EN858 Separator Range**
For the Treatment of Surface Water Runoff

Light liquid separator NSFR6

Connected surface area: 340 m²

Test report PIA2020-NW-2009-1039.02

Particle retention (Millisil W4)	84.35%
Total metal reduction*	63.26%
Dissolved metal reduction	0%
Particulate metal reduction*	0.75 x 84.35%

**The metal reduction factor was derived from the particle retention as 0.75 times the particle retention factor. This has reference for the assumption, that 75% of metal reduction is done by particle reduction.*

This document does not replace the test report.

PIA - Sustainable Certification
D. Schmitz

[Signature]
geprüft - tested - teste
Schmitz/Dorgeloh May 2021