

PERFORMANCE RESULTS

Marsh Industries Ltd.
Units 2-16 Addington Industrial Park, Irthlingborough Road
Little Addington, Northants NN14 4 AS Great Britain

EN 858-1
Separator systems for light liquids (e.g. oil and petrol)

Hydroil with coalescer

Test report PIA2017-AB-1607-1089

Material	Glass reinforced plastic	
Nominal hydraulic load	6.0 l/s, 10.0 l/s, 15.0 l/s	
	NS	Effluent
NS6	6	< 1.0 mg/l
NS10	10	< 1.0 mg/l
NS15	15	2.8 mg/l

Performance tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH
(PIA GmbH)
Hergenrather Weg 30
52074 Aachen, Germany

This document replaces neither the declaration
of performance nor the CE marking.



Notified Body
No.: 1739



Certified according to
ISO 9001:2008



Prüfinstitut für Abwassertechnik GmbH
Daniel Verschitz
geprüft - tested - testé

Daniel Verschitz

March 2017