



Prüfinstitut für
Abwassertechnik
GmbH

PERFORMANCE RESULTS

Portapura Limited.
Irthlingborough,
Northants NN9, Great Britain

EN 858-1
Separator systems for light liquids (e.g. oil and petrol)

“Marator Separator”

Test report PIA2018-AB-1804-1026.01

Material	Glass reinforced plastic
Nominal hydraulic load	6.0 l/s
Nominal Size	6
Effluent	< 0.1 mg/l
Class	I

Performance tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH
(PIA GmbH)
Hergenrather Weg 30
52074 Aachen, Germany

This document replaces neither the declaration
of performance nor the CE marking.



Notified Body
No.: 1739



Certified according to
ISO 9001:2008



Prüfinstitut für Abwassertechnik GmbH
Daniel Verschitz
Geprüft - tested - teste

Daniel Verschitz

August 2018